



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 216-07-M

Manufacturer: Internat Inc., 2045 Placentia Avenue, Costa Mesa, CA 92627

Trade Name(s): Sure-Board®, MagBoard

Product: 22-gauge steel sheet laminated to various forms of exterior substrate

Pertinent Code Section(s): 27-335.1

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Hardwood/Plywood & Veneer Association Laboratory and Testing Service (HPVA); Anderson Labs, Inc.

Test Report(s): HPVA T-12170 dated February 6, 2007
Anderson Labs, Inc. #659 dated March 19, 2007

Description: Sure-Board® panel is a 22-gauge steel sheet laminated to any form of exterior-type gypsum, concrete board, glassmat, fiber-reinforced gypsum or magnesium board. Sheet panels are used to resist wind and seismic lateral loads. It may also be used to prevent penetration from airborne debris, as well as impact and security protection for buildings.

Flame Spread Rating - 5
Smoke Developed Rating - 5

