



NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 166-07-M

Manufacturer: Intermat Inc., 2045 Placentia Avenue, Costa Mesa, CA 92627

Trade Name(s): Sure-Board®, MagBoard

Product: 22-gauge steel sheet laminated to any form of interior finish

Pertinent Code Section(s): 27-348

Prescribed Test(s): RS 5-5 (ASTM E84), Toxicity

Laboratory: Hardwood/Plywood & Veneer Association Laboratory and Testing Service (HPVA); Anderson Labs, Inc.

Test Report(s): HPVA T-12170 dated February 6, 2007
Anderson Labs, Inc. #659 dated March 19, 2007
E84 flame spread: 5, smoke developed: 5
Toxicity: LC₅₀=>100.0 grams

Description: Sure-Board® panel is a 22-gauge steel sheet laminated to any form of interior-type gypsum, concrete board, glassmat, fiber-reinforced gypsum or magnesium board. These sheets may be used on steel- or wood-framed structures. Sheet panels used to resist wind and seismic lateral loads on steel- and wood-framed buildings. It may also be used to prevent penetration from airborne debris, as well as impact and security protection for prison walls, banks, government buildings and schools.

Flame Spread Rating – 5
Smoke Developed Rating – 5

